

NOZZLE SCHEDULE						
ITEM	SIZE	RATING	TYPE	MATL.	REMARKS	NOTES
A	4"	N.P.T.	W.F.	C.S.	-	-
B	2"	N.P.T.	M.F.	C.S.	-	MONITORING PORT

LEFT SIDE

FRONT VIEW

NOTES:

A.

Material: H.R. Carbon Steel.

B.

Design Pressure: Atmospheric.

C.

Design Temperature: Ambient.

D.

Built & labeled per U.L. #58, UL 1746 and ACT100 specs.

E.

Exterior: Blast & apply min.100 mils DFT Fiberglass.

F.

Seal welded striker plates under all openings.

G.

All fittings to be protected for shipment.

H.

Customer to verify nozzle sizes, locations, and quantities.

APPROVAL FOR CONSTRUCTION
SCHEDULE A - MASTER TERMS &
CONDITION OF SALE*

☐

APPROVED AS DRAWN.

☐

APPROVED WITH NOTED CHANGES.
CONSTRUCTION WILL BE SCHEDULED
WHEN SIGNED DRAWING AND
CONFIRMED ORDER ARE RECEIVED.

SIGNATURE: _____

DATE: _____

*All pages of this Schedule A are incorporated by
reference and are a part of the additional terms of
the Master Terms & Conditions of Sale.
www.newberrytanks.com/masterterms.pdf

SALES ORDER:

Newberry Tanks
New Thinking

Phone: 870-735-4473 Fax: 870-735-3982

DESCRIPTION:

4000 GALLON 64" I.D. x 24'-0" O.A.L. DOUBLE WALL
ACT-100 TANK

CUSTOMER:

-

DATE:

06/26/23

SCALE:

DWG.#

NB04000DWA064250

WEIGHT (LBS): 6,672

All units inches
unless stated
otherwise

P.O.#

-

DRAWN BY: WR

SHEET 1 OF 1