

NOZZLE SCHEDULE								
ITEM	SIZE	RATING	TYPE	MATL	PROJ. IN	PROJ. OUT	REMARKS	NOTES
A	8"	N.P.T.	H.CPL.	C.S.	STD.	STD.	PRIMARY	EMERGENCY VENT OPENING
B	8"	N.P.T.	H.CPL.	C.S.	STD.	STD.	SECONDARY	EMERGENCY VENT OPENING
C	2"	N.P.T.	M.F.	C.S.	STD.	STD.	-	MONITORING PORT
D	4"	N.P.T.	W.F.	C.S.	STD.	STD.	-	-
E	2"	N.P.T.	W.F.	C.S.	STD.	STD.	-	-

LEFT SIDE

FRONT VIEW

NOTES:

A. Material: H.R. Carbon Steel.

B. Design Pressure: Atmospheric.

C. Design Temperature: Ambient.

D. Built & Labeled per U.L. #142 & SwRI 97-04 specifications.

E. Exterior: Blast & Apply one shop coat WHITE enamel.

F. All Fittings to be protected for shipment.

G. Customer to verify Nozzle sizes, locations, and quantities.

H. Saddles/Skids may require shimming or grouting during installation.

APPROVAL FOR CONSTRUCTION  
SCHEDULE A - MASTER TERMS &  
CONDITION OF SALE\*

☐ APPROVED AS DRAWN.

☐ APPROVED WITH NOTED CHANGES.  
CONSTRUCTION WILL BE SCHEDULED  
WHEN SIGNED DRAWING AND  
CONFIRMED ORDER ARE RECEIVED.

SIGNATURE: \_\_\_\_\_

DATE: \_\_\_\_\_

\*All pages of this Schedule A are incorporated by  
reference and are a part of the additional terms of  
the Master Terms & Conditions of Sale.  
www.newberrytanks.com/masterterms.pdf

SALES ORDER:

Phone: 870-735-4473

DESCRIPTION:  
4000 GALLON 64" I.D. x 24'-0" O.A.L. DOUBLE WALL  
FLAMESHIELD TANK

CUSTOMER: \_\_\_\_\_ P.O.# \_\_\_\_\_

DATE: 11/08/23 SCALE: \_\_\_\_\_ DWG.# NB04000FSD06407G DRAWN BY: WR

SHEET 1 OF 1

WEIGHT (LBS): 6574

All units inches  
unless stated  
otherwise