

	NOZZLE SCHEDULE						
	ITEM	SIZE	RATING	TYPE	MATL	REMARKS	NOTES
Ī	Α	20"	U.L.	M.W.	C.S.	SINGLE PUNCHED	TIGHT BOLTED
	В	8"	N.P.T.	H.CPL.	C.S.	PRIMARY	EMERGENCY VENT OPENING
	С	8"	N.P.T.	H.CPL.	C.S.	SECONDARY	EMERGENCY VENT OPENING
	D	2"	N.P.T.	M.F.	C.S.	-	MONITORING PORT
	Е	4"	N.P.T.	W.F.	C.S.	-	-
	F	6"	N.P.T.	H.CPL.	C.S.	-	- -
	G	2"	N.P.T.	W.F.	C.S.	-	-





## NOTES:

- A. Material: H.R. Carbon Steel.
- B. Design Pressure: Atmospheric.
- C. Design Temperature: Ambient.
- D. Built & labeled per U.L. spec. #142.
- E. Exterior: Gray primer included; see Sales Order for top coat.
- F. All fittings to be protected for shipment.
- G. Customer to verify nozzle sizes, locations, and quantities.
- H. Saddles/skids may require shimming or grouting during installation.

SCHEDULE A - MASTER TERMS &	
CONDITION OF SALE*	

☐ APPROVED AS DRAWN.

APPROVED WITH NOTED CHANGES, CONSTRUCTION WILL BE SCHEDULED WHEN SIGNED DRAWING AND CONFIRMED ORDER ARE RECEIVED.

SIGNATURE:\_\_\_\_

VAIE:

\*All pages of this Schedule A are incorporated by reference and are a part of the additional terms of the Master Terms & Conditions of Sale.

www.newberrytanks.com/masterterms.pdf

## Newberry Tanks New Thinking

72301 870-735-4473 www.newberrytanks.com

205 North Walker West Memphis, AR.

Equipment, LLC

∞

All units inches

unless stated

otherwise

Phone: 870-735-4473

8000 GALLON 96" I.D. x 21'-4" O.A.L. DOUBLE WALL SKID TANK

OMER:

DATE: 06/08/23 SCALE: DWG.# DRAWN BY: WR SHEET 1 OF 1