

NOZZLE SCHEDULE

ITEM	SIZE	RATING	TYPE	MATL	PROJ. IN	PROJ. OUT	REMARKS	NOTES
A	20"	UL	M.W.	C.S.	STD.	STD.	-	SINGLE PUNCHED, TIGHT BOLTED
B	10"	UL	ADAPT.	C.S.	STD.	STD.	PRIMARY	EMERGENCY VENT OPENING
C	10"	UL	ADAPT.	C.S.	STD.	STD.	SECONDARY	EMERGENCY VENT OPENING
D	3"	NPT	PIPE	C.S.	STD.	STD.	-	MONITORING PORT
E	3"	NPT	CPL.	C.S.	STD.	STD.	-	ATMOSPHERIC VENT OPENING
F	4"	NPT	H.CPL.	C.S.	STD.	STD.	-	-
G	6"	NPT	H.CPL.	C.S.	STD.	STD.	-	-



PLAN VIEW



FRONT VIEW

NOTES:

A. Material: H.R. Carbon Steel.
B. Design Pressure: Atmospheric.
C. Design Temperature: Ambient.
D. Built & Labeled per UL 142.
E. Exterior: One coat GRAY primer. See Sales Order for top coat.
F. All Fittings to be protected for shipment.
G. Customer to verify Nozzle sizes, locations, and quantities.

APPROVAL FOR CONSTRUCTION
SCHEDULE A - MASTER TERMS & CONDITION OF SALE*

☐ APPROVED AS DRAWN.

☐ APPROVED WITH NOTED CHANGES. CONSTRUCTION WILL BE SCHEDULED WHEN SIGNED DRAWING AND CONFIRMED ORDER ARE RECEIVED.

SIGNATURE:_____

DATE:_____

*All pages of this Schedule A are incorporated by reference and are a part of the additional terms of the Master Terms & Conditions of Sale. www.newberrytanks.com/masterterms.pdf

SALES ORDER:

WEIGHT (LBS): 17,750

Newberry Tanks
New Thinking

All units inches unless stated otherwise

Phone: 870-735-4473

DESCRIPTION:
20,000 GALLON 126" I.D. x 31'-0" SHELL HEIGHT
DOUBLE WALL VERTICAL TANK

CUSTOMER: -

P.O.# -

DATE: 06/24/26 | REV: 003 | DWG.# NB20000DWV126

DRAWN BY: WR

SHEET 1 OF 1

Newberry Tanks & Equipment, LLC 205 North Walker West Memphis, AR. 72301 870-735-4473 www.newberrytanks.com

This drawing may contain CONFIDENTIAL information and is intended only for the use of the specific individual(s) to which it is addressed